
sg-1 01.29.04

Color and Engraving Codes SG-2BN-2-Button Wallstation



Description

- Often used in entryways to turn lights on and off.
- Large, rounded buttons are easy to use.
- Backlit buttons with optional engraving make it easy to find and operate the control in low light conditions.
- Optional button engraving is angled up to the eye for easy reading.
- Functionality can be selected in the field.
- Status LEDs indicate which button was pushed
- Works with GRAFIK Eye 3000 and 4000 Series Control Units.
- Invokes functions in just one Control Unit or group of up to eight Control Units.

Finish and Engraving Options

- Available with button engraving.
- Three engraving options are available: General Engraving, Standard Engraving, & Non-Standard Text Engraving. For more details, refer to the seeTouch Ordering Guide (P/N 367-274) or visit the website at www.lutron.com/seetouch.

Field Selected Functionality

	DIP Switch Settings 5 6 7	Top button:	Bottom button:
Entrance Wallstation	on H H H	Selects scene 1.	Turns lights off.
Scene Selection		Selects scene 9.	Selects scene 10.
	+ + +	Selects scene 13.	Selects scene 14.
Panic Wallstation		Selects scene 16 (all lighting full on). Locks all other system controls.	Restores previous scene. Disables lockout.
Fine Tuning	† m • †	Temporarily brightens selected zone(s).	Temporarily dims selected zone(s).
Single-Partition Status Wallstation	i ii i ii	Control Units act in combination; movable wall open to make one large space.	Control Units act independently; movable wall closed to make two spaces.
Zone Lockout	* * * * *	Allows only temporary zone adjustment. Preset scene settings are not affected.	Disables zone lockout.
Sequencing	† † †	Loops continuously through scenes 5 to 16 using fade times entered at Control Units.	Turns sequencing off.



DIP Switches 8-10 are set at the factory. Do not change switch 8 or 9. Switch 10 controls the button backlight. Refer to product installation guide for more details.

\$LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

sg-9 01.29.04

Specifications

Power

Low-voltage type Class 2 (PELV). Operating voltage:12/24 V Direct Current.

Key Design Features

- Field-changeable button and faceplate assemblies allow easy customization.
- Front accessible DIP switches allow change of function without removing the unit from the wall.
- Meets IEC 801-2. Tested to withstand 15kV electro-static discharge without damage or memory loss.
- Faceplate snaps on with no visible means of attachment.
- Available as an "insert" style control for multi-ganging.
- Can be ganged to share a common faceplate with NovaT*® and Vareo® Dimmers. To order new Wallplates for multi-ganging, specify "R3" openings in a Lutron NovaT* multi-gang FB (fins broken) Series model number.
- Use Button Replacement Kits to change color, button configuration, or engraving.
- Button Replacement Kits may also be used to convert between non-insert and insert configurations.

System Communications and Capacity

- Low-voltage type Class 2 (PELV) wiring connects Wallstations to Control Units and other components.
- Up to 8 Control Units and 16 total Wallstations and/or Control Interfaces may be connected for a total of 24 control points.

Terminals


Accept up to two #18 AWG (1.0mm²) typical.

Environment

32-104°F (0-40°C). Relative humidity less than 90% non-condensing.


Mounting

Typical backbox dimensions: 95mm (3.74") high, 55mm (2.17") wide, 70mm (2.75") deep.




Dimensions


Front View



Side View



Back View



LUTRON SPECIFICATION SUBMITTAL

Job Number:

Model Numbers:

Color/Finish and Customizing Information

Color/Finish

Matte Finishes

White WH Ivory IV* Beige BE Gray GR* Brown BR Black BL

* GR, IV not currently backlighted

Metal Finishes

With Black Plastic Buttons (Standard)

BB Bright Brass **Bright Chrome** BC Bright Nickel BN Satin Brass SB Satin Chrome SC Satin Nickel SN Antique Brass QB Antique Bronze QΖ

Gloss Finishes

Available with Insert (I) style controls only. Ship with Claro® faceplates.

White GWH Light Almond GLA

Anodized Aluminum Finishes

Clear CLA Black BLA Brass BRA

Backlighting Notes:

Illuminated text (translucent text on buttons) is available for these colors: BL and BR (including all metal finishes).

Illuminated buttons (with black text on buttons) are available for these colors: WH, BE, GR, WH*, GLA*.

Multi-ganging

- Order Insert (I) style controls.
- To order new Wallplates for multi-ganging, specify "R3" openings in a Lutron NovaT*® multi-gang FB (fins broken) Series model number.

Examples:



Wallplate for 2 seeTouch Wallstations, Model # NT-R3-R3-FB-(color)




Wallplate for other Lutron controls and 2 seeTouch Wallstations, Model # NT-T8-R3-R3-FB-(color)

Note: New button inserts are not included with multi-ganging Wallplates.

Button Replacement Kits

Use Button Replacement Kits to change: colors, button configuration, engraving, between insert and non-insert versions.

Non-Insert Kit









Each Kit includes an adapter, button assembly, and wallplate

Insert Kit









LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:				
Job Number:					

^{*} Insert (I) style controls only

Wallstation Installation

DIP Switches

- Set DIP switches 1-4 to give the Wallstation a unique system address from 1 to 16.
- Set additional DIP switches (if any) to specify function as shown on the first page of the Wallstation's Specification Submittal.
- DIP switch 10 controls the button backlight.

Address	DIP Switch Settings					
	1	2	3	4		
1	+	1	†			
2	•	1	+	¥ ■		
3	•	†	+	■		
4	•	•	†	↓		
5	•	†	•	.		
6	•	†	•	†		
7	•	†	†	.		
8	•	†	†	†		
9	†	•	•	.		
10	÷	•	+	↓		
11	÷	•	†	□		
12	÷	•	†	↓		
13	†	†	•	.		
14	÷	†	•	· ·		
15	†	†	†	.		
16	V	V	†	†		
Reserved for	Reserved for GRX-PRG, if present on link.					

Low-voltage Class 2 (PELV) Wiring

- Use low-voltage Class 2 (PELV) wiring to daisy-chain Wallstations to Control Units and other components.
- Make connections inside the wallbox or in a switch/junction box with a maximum wire length of 8 feet (2.5m) from the link to the Wallstation.


When used with GRAFIK Eye 3000 Control Units

- Two #18 AWG (1.0mm²) conductors for common (terminal 1) and 12VDC (terminal 2). Ensure that the terminal 2 connection is wired correctly. Refer to GRAFIK Eye 3000 Series Specification Submittal.
- One shielded, twisted pair #18 AWG (1.0mm²) for data link (terminals 3 and 4).

When used with GRAFIK Eye 4000 Control Units

- Two #12 AWG (2.5mm²) conductors for common (terminal 1) and 24VFW (terminal 2). These won't fit in terminals. Connect as shown.
- One shielded, twisted pair #18 AWG (1.0mm²) for data link (terminals 3 and 4).
- Connect Drain/Shield as shown. Do not connect to Ground (Earth) or Wallstation. Connect the bare drain wires and cut off the outside shield.

Note: Use appropriate wire connecting devices as specified by local codes.



LUTRON. SPECIFICATION SUBMITTAL

Job Name: Model Numbers:

Job Number: